| AJAX | CE | "AS MANUFACTURING" LLC<br>S. Sklyarenka Str., 5, Kyiv, 04073, Ukraine<br>Registered in Ukraine: 42593133 |
|---|---|---|

DECLARATION OF PERFORMANCE
According to Construction Products Regulation EU No 305/2011
No 1922-CPR-2052
(issue 3)

1. Unique identification code of the product-type:
**Model: name ManualCallPoint (Red) Jeweller, model MCP.R.J-000-EU**
**Brand: AJAX**

2. Intended use/es:
**Fire detection and fire alarm systems. Manual call points. Components using radio links.**

3. Manufacturer:
**"AS MANUFACTURING" LLC, S. Sklyarenka Str., 5, Kyiv, 04073, Ukraine**

4. System(s) of AVCP:
**System 1.**

5. Harmonised standard/s:
**EN 54-11:2001, EN 54-11:2001/A1:2005, EN 54-25:2008, EN 54-25:2008/AC:2012.**

Notified body:
**1922 DEDAL, Attestation & Certification**

6. Declared performance:

| Essential characteristics | Performance | Harmonised technical specification |
|---|---|---|
| **EN 54-11:2001, EN 54-11:2001/A1:2005** | | |
| Nominal activation conditions / Sensitivity and Performance under fire conditions | Pass | 4.3.2, 4.4, 4.7.1, 4.7.4, 5.2, 5,3 |
| Operational reliability | Pass | 4.2, 4.3.1, 4.5, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.5 |
| | N/A | 4.6, 5.4 |
| Durability of operational reliability, temperature resistance | Pass | 5.7, 5.9 |
| | N/A | 5.8 |
| Durability of operational reliability, vibration resistance | Pass | 5.14, 5.15, 5.16, 5.17 |
| Durability of operational reliability, humidity resistance | Pass | 5.10, 5.12 |
| | N/A | 5.11, 5.19 |
| Durability of operational reliability, corrosion resistance | Pass | 5.13 |
| | N/A | 5.11 |
| Durability of operational reliability, electrical stability | Pass | 5.6, 5.18 |

| EN 54-25:2008, EN 54-25:2008/AC:2012 | | |
|---|---|---|
| Performance under fire conditions | Pass | 4.1, 4.2.2, 5.2, 8.3.7 |
| Response delay (response time to fire) | Pass | 8.2.3, 8.2.6 |
| Operational reliability | Pass | 4.2.1, 4.2.3, 4.2.4, 4.2.5, 4.2.6, 4.2.7, 5.3, 5.4, 6, 7, 8.2.2, 8.2.4, 8.2.5, 8.2.7, 8.2.8, 8.2.9, 8.3.1, 8.3.2, 8.3.3, 8.3.4, 8.3.6 |
| | N/A | 8.3.5 |
| Durability of operational reliability and response delay, temperature resistance | Pass | 8.3.9, 8.3.10, 8.3.11 |
| Durability of operational reliability, vibration resistance | Pass | 8.3.16, 8.3.17, 8.3.18, 8.3.19 |
| Durability of operational reliability, humidity resistance | Pass | 8.3.12, 8.3.14 |
| | N/A | 8.3.13 |
| Durability of operational reliability, corrosion resistance | Pass | 8.3.15 |
| Durability of operational reliability, electrical stability | Pass | 8.3.20 |

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

**Serhii Ivchun** — *Name*

**Attorney by virtue of the PoA** — *Function*

**Kyiv, Ukraine, July 02nd 2025**

*Signature*

| | | |
|---|---|---|
| AJAX | CE | **"AS MANUFACTURING" KFT.**<br>**S. Sklyarenka Str., 5, Kijev, 04073,**<br>**Ukrajna**<br>**Ukrajnában bejegyezve: 42593133** |

TELJESÍTÉSI NYILATKOZAT
Az építési termékekről szóló 305/2011/EU rendelet szerint
1922-CPR-2052 sz.
(3. szám)

1. A terméktípus egyedi azonosító kódja:
**Modell: name ManualCallPoint (Red) Jeweller, modell MCP.R.J-000-EU**
**Márka: AJAX**

2. Rendeltetésszerű használat/ok:
**Tűzérzékelő és tűzjelző rendszerek. Kézi hívópontok. Rádióösszeköttetést használó alkatrészek.**

3. Gyártó:
**"AS MANUFACTURING" LLC, S. Sklyarenka Str., 5, Kyiv, 04073, Ukrajna**

4. Az AVCP rendszere(i):
**1. rendszer.**

5. Harmonizált szabvány(ok):
**EN 54-11:2001, EN 54-11:2001/A1:2005, EN 54-25:2008, EN 54-25:2008/AC:2012.**

Bejelentett szervezet:
**1922 DEDAL, igazolás és tanúsítás**

6. Nyilatkozott teljesítmény:

| Lényeges jellemzők | Teljesítmény | Harmonizált műszaki előírás |
|---|---|---|
| **EN 54-11:2001, EN 54-11:2001/A1:2005** | | |
| Névleges aktiválási feltételek / Érzékenység és teljesítmény tűz esetén | Átad | 4.3.2, 4.4, 4.7.1, 4.7.4, 5.2, 5,3 |
| Működési megbízhatóság | Átad | 4.2, 4.3.1, 4.5, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.5 |
| | N/A | 4.6, 5.4 |
| A működési megbízhatóság tartóssága, hőmérséklet-ellenállás | Átad | 5.7, 5.9 |
| | N/A | 5.8 |
| Tartós működési megbízhatóság, rezgésállóság | Átad | 5.14, 5.15, 5.16, 5.17 |
| A működési megbízhatóság tartóssága, nedvességállóság | Átad | 5.10, 5.12 |
| | N/A | 5.11, 5.19 |
| Az üzembiztonság tartóssága, korrózióállóság | Átad | 5.13 |
| | N/A | 5.11 |
| A működési megbízhatóság tartóssága, elektromos stabilitás | Átad | 5.6, 5.18 |

| EN 54-25:2008, EN 54-25:2008/AC:2012 | | |
|---|---|---|
| Teljesítmény tűz esetén | Átad | 4.1, 4.2.2, 5.2, 8.3.7 |
| Válaszkésleltetés (tűzre adott válaszidő) | Átad | 8.2.3, 8.2.6 |
| Működési megbízhatóság | Átad | 4.2.1, 4.2.3, 4.2.4, 4.2.5, 4.2.6, 4.2.7, 5.3, 5.4, 6, 7, 8.2.2, 8.2.4, 8.2.5, 8.2.7, 8.2.8, 8.2.9, 8.3.1, 8.3.2, 8.3.3, 8.3.4, 8.3.6 |
| | N/A | 8.3.5 |
| A működési megbízhatóság és a válaszkésleltetés tartóssága, hőmérséklet ellenállás | Átad | 8.3.9, 8.3.10, 8.3.11 |
| Tartós működési megbízhatóság, rezgésállóság | Átad | 8.3.16, 8.3.17, 8.3.18, 8.3.19 |
| A működési megbízhatóság tartóssága, nedvességállóság | Átad | 8.3.12, 8.3.14 |
| | N/A | 8.3.13 |
| Tartós működési megbízhatóság, korrózióállóság | Átad | 8.3.15 |
| A működési megbízhatóság tartóssága, elektromos stabilitás | Átad | 8.3.20 |

A fent meghatározott termék teljesítménye megfelel a bejelentett teljesítmény(ek)nek. Ezt a teljesítménynyilatkozatot a 305/2011/EU rendeletnek megfelelően a fent megjelölt gyártó kizárólagos felelőssége mellett adjuk ki.

| | | |
|---|---|---|
| **Kijev**<br>*Helyszín* | **Szerhij Ivcsun**<br>*Név*<br>**Név Ügyvéd a megbízási szerződés alapján**<br>*Funkció* | **Ellenőrizze az eredeti alkalmazáshoz csatolt aláírást.**<br>*Dátum*<br>**január 16. 2024** |